



# EXPLOSION PROTECTION

## CERTIFICATE OF CONFORMITY

Cert NO.GYJ17.1036X

This is to certify that the product

Pressure, Differential pressure, Temperature switches

manufactured by BETA B.V

(Address: Verrijin Stuartlaan 22, 2288 EL Rijswijk, The Netherlands.)

which model is W3/W8/W9 Series, V5 Series

Ex marking Ex d IIC T5/T6 Gb

product standard /

drawing number 30.09.01; 30.09.49; 30.09.50; 30.09.81; 30.09.82; 30.09.83

has been inspected and certified by NEPSI, and that it conforms  
to GB 3836.1-2010, GB 3836.2-2010

This Approval shall remain in force until 2022.01.22

**Remarks** 1. Conditions for safe use are specified in the attachment(s) to this certificate.  
2. Symbol "X" placed after the certification number denotes specific conditions of use,  
which are specified in the attachment(s) to this certificate.

Director



National Supervision and Inspection Centre for  
Explosion Protection and Safety of Instrumentation

Issued Date 2017.01.23

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road  
Shanghai 200233, China

<http://www.nepsi.org.cn>  
Email: [info@nepsi.org.cn](mailto:info@nepsi.org.cn)

Tel: +86 21 64368180  
Fax: +86 21 64844580





# 防爆合格证

证号: GYJ17.1036X

由 BETA B.V

制造的产品:

(地址: Verrijin Stuartlaan 22, 2288 EL Rijswijk, The Netherlands.)

名称 压力/差压/温度开关

型号规格 W3/W8/W9系列, V5系列

防爆标志 Ex d IIC T5/T6 Gb

产品标准 /

图样编号 30.09.01; 30.09.49; 30.09.50; 30.09.81; 30.09.82; 30.09.83

经图样及技术文件的审查和样品检验, 确认上述产品  
符合 GB 3836.1-2010、GB 3836.2-2010 标准,

特颁发此证。

本证书有效期: 2017年1月23日至2022年1月22日

备注 1. 安全使用注意事项见本证书附件。

2. 证书编号后缀“X”表明产品具有安全使用特殊条件, 内容见本证书附件。

站长

国家级仪器仪表防爆安全监督检验站

颁发日期二〇一七年一月二十三日

本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号  
邮编: 200233

网址: [www.nepsi.org.cn](http://www.nepsi.org.cn)  
Email: [info@nepsi.org.cn](mailto:info@nepsi.org.cn)

电话: +86 21 64368180  
传真: +86 21 64844580