



# Certificate / Certificat Zertifikat / 合格証

BETA B.V. 080432 C001

*exida* hereby confirms that the:

## BETA Pressure, Temperature and Vacuum Switches

The manufacturer  
may use the mark:



### BETA B.V. Rijsvijk – The Netherlands

Have been assessed per the relevant requirements of:

**IEC 61508 : 2010 Parts 1-2**

and meets requirements providing a level of integrity to:

**Systematic Capability: SC 3 (SIL 3 Capable)**

**Random Capability: Type A, Route 1<sub>H</sub> Element**

**PFH/PFD<sub>avg</sub> and Architecture Constraints  
must be verified for each application**

#### Safety Function:

The air-relay / micro switch will de-energize and open when the input pressure, or temperature, rises above, or fails below, the set-point within the stated safety accuracy.

#### Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

Revision 2.0 September 12, 2023  
Surveillance Audit Due  
September 30, 2026



Evaluating Assessor

Certifying Assessor

BETA B.V. 080432 C001

**Systematic Capability: SC 3 (SIL 3 Capable)**

**Random Capability: Type A, Route 1<sub>H</sub> Device**

**PFH/PFD<sub>avg</sub> and Architecture Constraints must be verified for each application**

**Systematic Capability:**

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

**Random Capability:**

The SIL limit imposed by the Architectural Constraints must be met for each element.

**IEC 61508 Failure Rates in FIT\***

Device	$\lambda_{Safe}$	$\lambda_{Dang}$
Pressure switches C.-P....- air-relay	313	209
Pressure switches W.-P....- or C.-P....- or B.-P....- micro-switch	190	93
Temperature switches C.-T....- air-relay	301	196
Temperature switches W.-T....- or C.-T....- or B.-T....- micro-switch	164	98
Vacuum switches W.-V....- or C.-V....- or B.-V....	86	53
Differential pressure switches W.-D....- or C.-D....- or G.-D ....	364	204

\* FIT = 1 failure / 10<sup>9</sup> hours

**SIL Verification:**

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD<sub>avg</sub> considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

**Assessment Report:** Beta BV 0804-032-C R004 V2 R0

**Safety Manual:** BETA Safety manual SP 273.C from 08-2023

